



# Certificate of Compliance

**Certificate:** 70029873

**Master Contract:** 151933

**Project:** 70029873

**Date Issued:** August 12, 2015

**Issued to:** Killark Electric Manufacturing Co.

3940 Dr. Martin Luther King Dr.  
St. Louis, MO 63113  
USA  
Attention: Brian Pegg

*The products listed below are eligible to bear the CSA Mark shown*



*Siros Ghanbarzadeh*

**Issued by:** Siros Ghanbarzadeh

## **PRODUCTS**

**CLASS 4418 02** - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

**Class I, Div. 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G; Class III:**

Conduit unions, Cat. Nos. GUF, GUM, and GUMM, followed by -1, -2 or -3, conduit size 1/2, 3/4, and 1 inch, raintight and concrete tight conduit unions for use in hazardous locations, Class I, Groups A, B, C and D; and Class II, Groups E, F and G; Class III.

**Class I, Div. 1, Groups C and D; Class II, Div. 1, Groups E, F and G; Class III:**

Cat. Nos. GUF or GUM followed by -4, -5, -6, -7 or -8, conduit size 1-1/4, 1-1/2, 2, 2-1/2 and 3 inch, raintight and concrete tight conduit unions for use in hazardous locations, Class I, Groups C and D; and Class II, Groups E, F and G; Class III.

Cat. Nos. GUF or GUM followed by -9 and -0, conduit size 3-1/2 and 4 in., raintight and concrete tight conduit unions for use in hazardous locations, Class I, Groups C and D; and Class II, Groups E, F and G; Class III.



**Certificate:** 70029873

**Master Contract:** 151933

**Project:** 70029873

**Date Issued:** August 12, 2015

---

### **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0.10-M1985, (reaffirmed 2014) - General Requirements - Canadian Electrical Code, Part II

CSA Standard C22.2 No. 30-M1986, (reaffirmed 2012) - Explosion-Proof Enclosures for Use in Class I-Hazardous Locations

CSA Standard C22.2 No. 25-1966, (reaffirmed 2014) - Enclosure for use in Class II, Groups E, F and G; Hazardous Locations

### **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The following markings are stamped into the conduit fittings:

- Submitter's name or trade Mark;
- Catalogue number or Type Designation;
- Hazardous Locations Designation;
- CSA Monogram (cCSAus)